



Certificate of Compliance

Certificate: 70013976

Master Contract: 262275

Project: 70013976

Date Issued: February 06, 2015

Issued to: Canovate Elektronik Endustri ve Ticaret A.S
Eksioglu Mah Atabey No12 Cekmekoy
Istanbul, Istanbul 34794
TURKEY
Attention: Kivanc Ilal

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Frank Gessner*
Frank Gessner

PRODUCTS

CLASS - C386213 - INFORMATION TECHNOLOGY EQUIPMENT-(CSA 60950-1-07, Second Edition)

IT Cabinet Equipment Rack with Air Conditioner , “Micro DC” Models 24U, 36U and 42U, Series CPJ-c-xyzA-aaa-bbb-vv, cord connected; AC unit input rated 230 V ac, 60 Hz, 11.4 A max.

Notes:

- 1. The model designations have additional suffixes consisting of alphanumeric characters (c is 7 or 9 for colour; xx is 24, 36 or 42 for height; y is 6 or 8 for width; z is 0 or 2 for depth; A is factory assembled; aaa is T2K or T4K for cooling); bbb is for configuration; vv is for revision.*
- 2. Models are certified as a component for use with other certified equipment, where the suitability of the combination is to be determined by CSA or the Authority having Jurisdiction.*

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No. 60950-1-07 + Amendment 1: 2011 - Information Technology Equipment - Safety - Part 1: General Requirements



Certificate: 70013976

Project: 70013976

Master Contract: 262275

Date Issued: February 06, 2015

CONDITIONS OF ACCEPTABILITY

1. This component has been evaluated for the spacings required in accordance with CAN/CSA C22.2 No. 60950-1:2007, Cl. 2.10.
2. A 20A branch circuit is to be used in the end system, as per the Canadian Electrical Code, to supply the Air Conditioning unit.
3. The equipment is installed in the field by trained personnel in accordance with the installation instructions provided with the equipment for correct supply and protective earthing connection.
4. Bonding terminals provided with this equipment have not been evaluated as protective earth terminals.
5. For Rack-Mounted Equipment, Trained Personnel Installed Equipment and Components: All such units are Certified as components of other Certified equipment where the suitability of each combination is to be determined by CSA.
6. The equipment has been tested to a maximum ambient of 55 °C.
7. The cabinet with wheels (castors) has not been tested on models 36U and 42U and, therefore, only stationary feet can be used for these models.



Supplement to Certificate of Compliance

Certificate: 70013976

Master Contract: 262275

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70013976	Feb. 6, 2015	New model certification for "MicroDC" Models 24U, 36U and 42U, Series CPJ, for Canada under Class 3862-13. Includes completed Initial Factory Inspection (IFE) for new factory ID 4870009. Equipment meets the following applicable requirements: CSA C22.2 No. 60950-1-07 + Ammend. 1:2011. Report in Documentum.